



Daily Fire & Crime Log - May 2023

Case Number	Incident Type	Location	Occurrence Date	Reported Date	Status/Disposition
202305010108	Fire Alarm	30 Bobcat Lane Apartment 107 Swainsboro, GA	5/01/2023 11:29 a.m.	5/01/2023 11:29 a.m.	Closed-Resolved. Alarm caused by dust from construction renovation. Corvias representatives canceled emergency response.
202305020109	Poss. of Marijuana & Drug Related Objects (Misdemeanor)	4 Bobcat Lane Apartment 207 Swainsboro, GA	5/02/2023 1:57 p.m.	5/02/2023 1:57 p.m.	Closed-Resolved. Cleared by Arrest.
202305040110	Panic Alarm Test	131 College Circle Swainsboro, GA	5/04/2023 8:14 a.m.	5/04/2023 8:14 a.m.	Closed-Resolved. EGSC Public Safety conducted campus wide test of panic alarms for operability.
202305040111	Forgery / Theft by Taking	131 College Circle Swainsboro, GA	4/27/2023 5:00 p.m.	5/04/2023 11:00 a.m.	Open Case.
202305100112	Fire Alarm	30 Bobcat Lane Apartment 107 Swainsboro, GA	5/10/2023 11:07 a.m.	5/10/2023 11:07 a.m.	Closed-Resolved. Alarm caused by dust from construction renovation. Corvias representatives canceled emergency response.
202305100113	Red Phone Inspection	131 College Circle Swainsboro, GA	5/10/2023 7:25 a.m.	5/10/2023 7:25 a.m.	Closed-Resolved. EGSC Public Safety conducted campus wide test of 911 Emergency Red Phones for operability.

Case Number	Incident Type	Location	Occurrence Date	Reported Date	Status/Disposition
202305110114	Fire Alarm	30 Bobcat Lane Laundry Room Swainsboro, GA	5/10/2023 12:53 p.m.	5/10/2023 12:53 p.m.	Closed-Resolved. Alarm caused by fire alarm maintenance. Fire Department notified.
202305160115	Fire Alarm	30 Bobcat Lane Lobby Area Swainsboro, GA	5/16/2023 11:23 a.m.	5/16/2023 11:23 a.m.	Closed-Resolved. Alarm caused by construction / renovation. Corvias representatives canceled emergency response.
202305160116	Fire Alarm	30 Bobcat Lane Janitorial Closet Swainsboro, GA	5/16/2023 2:07 p.m.	5/16/2023 2:07 p.m.	Closed-Resolved. Alarm caused by construction / renovation. Corvias representatives canceled emergency response.
202305170117	Fire Alarm	30 Bobcat Lane Laundry Room Swainsboro, GA	5/17/2023 2:10 p.m.	5/17/2023 2:10 p.m.	Closed-Resolved. Alarm caused by construction / renovation. Swainsboro Fire Department responded.
202305170118	Fire Alarm	30 Bobcat Lane Apartment 301 Swainsboro, GA	5/17/2023 3:00 p.m.	5/17/2023 3:00 p.m.	Closed-Resolved. Alarm caused by construction / renovation. Corvias representatives canceled emergency response.